

## **Below Grade Wall Assembly**

Assembly # MB-01

Description: 203.2mm (8") Concrete wall with 38mm (1.5") expanded polystyrene (Type 1) continuous insulation and 38x89 (2x4) studs at 610mm (24") o/c with RSI 2.11 (R 12) fiberglass insulation. Interior finished with 12.7mm (1/2") gypsum board.

Layer	Assembly Components (layer listed from exterior to interior)	RSI Value	R Value
1	203.2mm (8") concrete wall	0.08128	0.461529
2	38mm (1.5") expanded polystyrene (Type 1)	0.988	5.610124
3	38x89 (2X4) @ 610mm (24") o/c with RSI 2.11 (R 12) Fiberglass batt *	1.71184	9.720278
4	6 mil. Polyethylene	N/A	N/A
5	12.7mm (1/2") gypsum board	0.07747	0.439895
6	Inside Air Film	0.12	0.681392

Total 2.98 16.9

Note:

The thermal resistance values of each continuous layer incorporated in the assembly are from A-9.36.2.4.(1)D.

 $\begin{array}{c} \text{RSI}_{\text{parallel}} = & 100 \\ \text{Parallel Heat Flow Calculation:} & \frac{\text{% area of framing}}{\text{RSI}_{\text{F}}} & + \frac{\text{% area of cavity}}{\text{RSI}_{\text{C}}} \\ \end{array}$ 

% Area of Framing 13% Value of the area of framing member obtained from Table A-9.36.2.4.(1)A % Area of Cavity 87% Values of the area of cavity obtained from Table A-9.36.2.4.(1)A

RSI Framing 0.7565
RSI Cavity 2.11
RSI Parrallel \* 1.71184

Note: The above values and references are from the 2010 National Building Code of Canada. This document is intended to be used for reference purposes. The assembly components shall be detailed in a cross section on the submitted plans.

used for reference purposes. The assembly components shall be detailed in a cross section on the submitted plans.							
RSI <sub>eff</sub> =	2.98	(m²·K)/W	R <sub>eff</sub> =	16.9	(h·ft²·ºF)/Btu		
eff = effective thermal resistance							