

Below Grade Wall Assembly

Assembly # MB-05

Description: 203.2mm (8") Concrete wall with 38x140 (2x6) studs at 610mm (24") o/c with 114.3mm (4.5") 2lb sprayed polyurethane foam cavity insulation. Interior finished with 12.7mm (1/2") gypsum board.

Layer	Assembly Components (layer listed from exterior to interior)	RSI Value	R Value
1	203.2mm (8") concrete wall	0.08128	0.461529
2	38x140 (2X6) @ 610mm (24") o/c with RSI 4.11 (R23.3) 2lb sprayed polyurethane foam*	3.11602	17.69358
3	25.4mm (1") Air space	0.18	1.022087
4	12.7mm (1/2") gypsum board	0.07747	0.439895
5	Inside Air Film	0.12	0.681392

Total 3.57 20.3

Note:

The thermal resistance values of each continuous layer incorporated in the assembly are from A-9.36.2.4.(1)D.

% Area of Framing 13% Value of the area of framing member obtained from Table A-9.36.2.4.(1)A % Area of Cavity 87% Values of the area of cavity obtained from Table A-9.36.2.4.(1)A

RSI Framing 1.19
RSI Cavity 4.11
RSI Parrallel * 3.11602

Note: The above values and references are from the 2010 National Building Code of Canada. This document is intended to be used for reference purposes. The assembly components shall be detailed in a cross section on the submitted plans.

RSI _{eff} =	3.57	(m²·K)/W	R _{eff} =	20.3	(h·ft².ºF)/Btu
eff = effectiv	e therma	l resistance			